



Philippine
Overseas
Employment
Administration

Republic of the Philippines
Department of Labor and Employment
BFO Building, Ortigas Avenue cor. EDSA, Mandaluyong City 1550
Website: www.poea.gov.ph
E-mail: connect@poea.gov.ph
Hotlines: 8722-1144, 8722-1155

BID BULLETIN No. 09-A
Series of 2021

Please be advised of the changes for the following projects:

1. ***“Procurement of High-Performance Uninterruptible Power Supply (UPS) – Five (5) Units of 5Kva and Five Hundred (500) Units 650va for Premium Power Protection per ITB 14-2021”.***

Procurement of High-Performance Uninterruptible Power Supply (UPS) – Five (5) Units of 5Kva and Five Hundred (500) Units 650va for Premium Power Protection per ITB 14-2021	
Supplier’s Clarification	ICT Recommendation
1) Should the bidder provide the installation, including the electrical system, for the supply and delivery of a 5kVA Uninterruptible Power Supply (UPS)? If this is the case, the bidders will need a site survey.	Approved
2) On the runtime and percentage load of 5Kva UPS	Follow the specifications. Check the runtime graph and efficiency graph on the product website.
3) On the submission of Legal Documents under Technical Component Envelope.	Please do follow the Chronological Order in the Checklist of Requirements as stated in the PBDs
4) All bidders requested to extend the delivery period from 45 calendar days to 90-120 calendar days. The delivery lead time of the distributor is from 90 – 120 calendar days	Only 90 calendar days of delivery. No extension and consideration,
5) The bidder inquired if they may submit Single Largest Completed Contracts (SLCC) related to the supply and delivery of ICT equipment with UPS.	The BAC answered that bidders can submit SLCC related to supply and delivery of ICT equipment with UPS. The contract similar to project refers to the Procurement of UPS and bidder must have a completed contract within five (5) years prior to the deadline for the submission and receipt of bids.
6) On the request for ocular inspection, bidders should send a request through the BAC.	Approved, for coordination with ICT Branch
7) Query on the product certifications under the Conformance indicated in the TOR: Can the bidder offer products with any of the following product certifications/safety marks: CE, EAC, IRAM, RCM, or VDE, as not all product certifications are	No, follow the specifications in the Terms of Reference (TOR)

applicable to a specific manufacturer?	
8) For the specification of 5kVA APC Infrastructure manager, only APC products can comply with the TOR.	Follow the specifications in the Terms of Reference (TOR)
9) Is the 5Kva UPS is a minimum requirement or can bidder's offer a little higher specification.	Specifications should be equivalent or higher
10) Stated TOR, the maximum configurable power is 4,500watts, if 5Kva is minimum requirement, can the maximum configuration of 4.5kw be removed?	kVA is a measure of apparent power it tells you the total amount of power in use in a system. In a 100% efficient system kW = kVA electrical systems. However electrical systems are never 100% efficient and therefore not all of the systems apparent power is being used for useful work output. While the kW is the amount of power that is converted into a useful output. kW is therefore as actual power or working power. As such, we recommend that the maximum configurable power in W and VA is 4.5kWatts / 5.0kVA.
11) Under Bidder Qualification Bullet No.3, are we referring that a Certified Engineer is employed to the Bidders and has been trained by the Manufacturer of offered solution? Having an employed Certified Engineers by Manufacturer is a proof that the Bidders is capable of handling the support especially the requirement is Volume/Large Quantity.	Yes, Certified Engineer is employed to winning bidder or to the manufacturer and has been trained.
12) For the 5KVA, does electrical work and materials should be provided by the Bidders OR just Supply/Start Up only?	Supply/Start Up only
13) Submission and Opening of Bids	From November 22, 2021 10:30 A.M. to November 29, 2021 10:30 A.M. (If November 29, 30 and December 1, 2021 declares the Malacañang as a Non-Working day for a three (3) day National Vaccination drive. The Submission and Opening Of Bids will be move to December 02, 2021 10:30 A.M.)

2. ***“Procurement of Six (6) Units Server and Two (2) Units Network Attached Storage for POEA Infrastructure Modernization Program per ITB 15-2021”.***

Procurement of Six (6) Units Server and Two (2) Units Network Attached Storage for POEA Infrastructure Modernization Program per ITB 15-2021		
Per TOR / Bid Data Sheet	Supplier's Request	ICT Recommendation
Bid Data Sheet (page 18) ITB Clause 5.3 For the Purpose, contracts similar to the Project shall be a. <i>Refer to the Procurement of servers</i> Have been completed within five (5) years	May we humbly request that contract related to the “Supply and Delivery of Information Technology (IT) Equipment” be accepted as a similar contract	Approved

prior to the deadline for the submission and receipt of bids.		
Delivered, Weeks/Moths 45 calendar days upon receipt of NTP/PO	May we humbly request to relax this requirement by extending the delivery period to 90 calendar days upon receipt of NTP/P.O.	Approved the 90 calendar days of delivery. No extension and consideration,
Processor: 6 x Intel Xeon Platinum 8360Y 2A0GHz up to 3.90GHz, 24 cores, 48 Threads	May humbly request to relax this requirement by revising it to: Processor: 6 x Intel Xeon Platinum <ul style="list-style-type: none"> • Base Frequency: 2.40GHz • Max Turbo Frequency: 3.90 GHz • Total Cores: 24 • Total Threads: 48 	Approved
Scope of Work and Services Item 1. Shall supply and deliver branded seven (7) units server and two (2) units network attached storage, delivery should be free of charge		The Scope of Work and Services for item 1 shall revise and read as: Item 1. Shall supply and deliver branded six (6) units server and two (2) units network attached storage, delivery should be free of charge
Submission and Opening Bids	From November 22, 2021 1:00 P.M. to November 29, 2021 11:00 A.M.(If November 29, 30 and December 1, 2021 declares the Malacañang as a Non-Working day for a three (3) day National Vaccination drive. The Submission and Opening Of Bids will be move to December 02, 2021 11:30 A.M.)	

For the information of all concerned.

18 November 2021.


DIR. VIRGILIO L. CARREON JR.
 Chairperson
 POEA Bids and Awards Committee

Received by the Bidder:

 Date : _____